



WaterMark

Certificate of Conformity

Pro-Switch Pty Ltd grants to the WaterMark Approved User:

Nymet Australia Pty Ltd

Trading as Nymet Australia Pty Ltd

the right to use the WaterMark as shown above in conjunction with the Certificate No. on product/s as identified in the WaterMark Schedule and as listed on the WaterMark database www.abcb.gov.au/Product-Certification/WaterMark-Certification-Scheme which have been shown to comply with the appropriate Applicable Specification referred to below and as amended from time to time. The WaterMark User is granted a licence to use the WaterMark subject to the rules governing the use of the WaterMark.

Product Type: Pressure Reduction Valve
Product Use: Water Supply
Brand: NYMET
Certification Specification: AS 1357.2:2023 Valves primarily for use in heated water systems
Part 2: Control valves
Conditions or Limitations: To be installed in accordance with Plumbing Code of Australia (PCA)

Issue Date: 24th April 2026
Initial Issue Date: 19th October 2018
Expiry Date: 30th June 2028

Simon Clarke
General Manager

Certificate No.: 32003

This Certificate is issued by a JAS-ANZ accredited certification body. The ABCB and JAS-ANZ do not in any way warrant, guarantee or represent that the product the subject of this Certificate conforms to the WaterMark Certification Scheme Rules, nor accepts any liability arising out of the use of the product. The ABCB disclaims to the extent permitted by law, all liability (including negligence) for claims of losses, expenses, damages and costs arising as a result of the use of the product(s) referred to in this Certificate. The WaterMark Certification Scheme is a conformity assessment scheme based on ISO/IEC 17067. This Certificate may only be reproduced in its entirety.



Pro-Switch Pty Ltd
ABN 37 121 022 366
PO Box 3082
Norman Park QLD 4170 Australia
Phone: +61 448 235 770
Email: support@pro-switch.com.au
www.pro-switch.com.au



Certificate Number: 32003
Issue Date: 24/04/2026
Revision: CR03



WaterMark Certification Schedule

WaterMark Approved User	Nymet Australia Pty Ltd ABN: 54 139 368 246
Approved User Address	37 Stanbel Road Salisbury Plain SA 5109 AUSTRALIA www.nymet.com.au
Certificate Number	32003
Certification Standard	AS 1357.2:2023 Valves primarily for use in heated water systems Part 2: Control valves

Product List

Model ID	Brand Name	Product Description	Material Designation	Leadfree Compliant
PRVM20M20	NYMET	DN20 - Outlet Pressure 100 to 600kPa Max. Inlet Working Pressure 1600kPa 3/4" Male Threaded End Connections (Straight Though or 90-degree Configuration)	30% Glass Filled Nylon	N/A



ABN 37 121 022 366

Pro-Switch Pty Ltd
PO Box 3082
Norman Park QLD 4170 Australia
Phone: +61 448 235 770
Email: support@pro-switch.com.au
www.pro-switch.com.au



Certificate Number: 32003
Issue Date: 24/04/2026
Revision: CR03