



# WaterMark

## Certificate of Conformity

Australian Certification Services Pty Ltd grants to the WaterMark Approved User:

# White International Pty Ltd

Trading as White International Pty Ltd

the right to use the WaterMark as shown above in conjunction with the Certificate No. on product/s as identified in the WaterMark Schedule and as listed on the WaterMark database [www.abcb.gov.au/Product-Certification/WaterMark-Certification-Scheme](http://www.abcb.gov.au/Product-Certification/WaterMark-Certification-Scheme) which have been shown to comply with the appropriate Applicable Specification referred to below and as amended from time to time. The WaterMark User is granted a licence to use the WaterMark subject to the rules governing the use of the WaterMark.

Product Type: Rainwater/Mains Supply Changeover Device  
Product Use: Water Supply  
Brand: Rainsaver  
Certification Specification/s: WMTS 477:2016 Rainwater/Mains Supply Changeover Device

Paul Greig  
General Manager

Issue Date: 24<sup>th</sup> August 2018  
Initial Issue Date: 24<sup>th</sup> July 2009  
Expiry Date: 12<sup>th</sup> July 2023

Certificate No.: 23022

This Certificate is issued by a JAS-ANZ accredited certification body. The ABCB and JAS-ANZ do not in any way warrant, guarantee or represent that the product the subject of this Certificate conforms to the WaterMark Certification Scheme Rules, nor accepts any liability arising out of the use of the product. The ABCB disclaims to the extent permitted by law, all liability (including negligence) for claims of losses, expenses, damages and costs arising as a result of the use of the product(s) referred to in this Certificate. The WaterMark Certification Scheme is a conformity assessment scheme based on ISO/IEC 17067. This Certificate may only be reproduced in its entirety





# WaterMark Certification Schedule

The WaterMark User	White International Pty Ltd ABN: 48 000 119 380 52-60 Ashford Avenue, Milperra, NSW 2214 AUSTRALIA Website: <a href="http://www.whiteint.com.au">www.whiteint.com.au</a>
Certificate Number	23022
Evaluation Specification/s:	WMTS 477:2016 Rainwater/Mains Supply Changeover Device

## Product Listing

Model Identification	Model Name	Brand Name	Product Description
803128	BIA- RAINSAVER MK4E	Bianco Rainsaver	DN20 Rainwater/Mains Supply Changeover Device for use with self prime pumps Max Operating Pressure/Temperature 800kPa/40°C Max Flow rate 100L/min Electric version
805791	UP-RSMK4E	Bianco Rainsaver	DN20 Rainwater/Mains Supply Changeover Device for use with self prime pumps Max Operating Pressure/Temperature 800kPa/40°C Max Flow rate 100L/min Electric version
804683	Bia-Rainsaver Mk6-200kPa	Bianco Rainsaver	DN20 Rainwater/Mains Supply Changeover Device to be Used in Conjunction with Rainsaver Pump Packages Max Operating Pressure/Temperature 1000kPa/40°C Max Flow rate 120L/min (Pump) 40L/min (Mains) 200kPa Set Pressure
804684	Bia-Rainsaver Mk6-300kPa	Bianco Rainsaver	DN20 Rainwater/Mains Supply Changeover Device to be Used in Conjunction with Rainsaver Pump Packages Max Operating Pressure/Temperature 1000kPa/40°C Max Flow rate 120L/min (Pump) 40L/min (Mains) 300kPa Set Pressure

