

FC Series Close-Coupled, Cast Iron Centrifugal Pumps





1. Introduction

Congratulations on your purchase of a **BiANCO NXT FC Series** pump.

The FC range is a family of Close-Coupled, Cast Iron, End Suction Centrifugal Pumps suitable for clean water transfer applications. This range of pumps is often employed for Vat Wash or CIP (Clean in Place) duties with water up to 85 °C

2. Key Features

- Compact, simple design
- Close coupled 240V single phase TEFC motor with in-built auto reset thermal overload
- · Quiet and reliable
- Floating ring nose seal for higher efficiency
- Cast Iron body with cataphorosis corrosion inhibitor treatment. 304 grade stainless steel, impeller, seal support and pump shaft. Nitrile o-rings

This pump is intended to transfer clean water or other liquids with physical and chemical properties similar to water. Ph must be between 6.5 and 8.5 and temperatures between 3°C to 85 °C.

It must only be used to transfer clean water and other non-corrosive liquids with low viscosity. It must not be used to transport inflammable, explosive, gasified liquids and liquids containing solid particles.

It can be used to pump clean water from lakes, rivers, tanks, small scale irrigation and for general water transfer. It must not be used to drain spas or swimming pools.

3. Contents

| 1. | Introduction | 2 |
|-----|--|-------|
| 2. | Key Features | 2 |
| 3. | Contents | 2 |
| 4. | Warnings | 3 |
| | Symbols used in this manual | |
| 6. | Technical Specifications | 4 |
| 7. | Electrical Connections | 5 |
| 8. | General installation and startup notes | 6 - 7 |
| 9. | Exploded View | 8 |
| 10. | Warranties - Terms and Conditions | 9 |
| 11. | Trouble Shooting Guide | 10 |

4. Warnings

| ③ | Read the manual carefully before starting |
|----------|---|
| <u> </u> | Prior to starting installation or any maintenance the pump must be disconnected from the power supply and pressure relieved from the system including controller, pump and associated pipework. |
| 4 | Any changes or modification to the wiring must be carried out by suitably qualified personnel. |
| 4 | A qualified electrician should correctly size and install circuit breakers to protect the power supply. The fitment of additional surge protection is recommended. |
| 4 | Never open the controller cover or pump terminal box cover while the pump is connected to electrical supply. |
| • | This appliance is not intended for use by persons (including children) with reduced physical, sensory or mental capabilities, or lack of experience and knowledge, unless they have been given supervision or instruction concerning use of the appliance by a person responsible for their safety. Children should be supervised to ensure that they do not play with the appliance. |
| <u> </u> | To avoid excessive thermal shock to the motor the pump should not start more than 20 times in any one hour period. |
| <u> </u> | Ensure that the installation will comply with all applicable local regulations. |

5. Symbols used in this manual

| 4 | Warning - Electrical safety |
|----------|--|
| | Warning – Potential consequences of use outside of intended application(s). Includes environmental condition warnings. |
| • | Mandatory warning |
| | Warning to disconnect power |
| ③ | Read carefully |

6. Technical Specifications

| SPECIFICATIONS - SINGLE PHASE | | | | | |
|-------------------------------|--|-----------------------|-------------|--|--|
| | FC75M | FC150M | FCT150M | | |
| Maximum head | 36m | 22m | 57.5 m | | |
| Maximum flow | 110 l/min | 550 l/min | 160 l/min | | |
| Input power | | 230V Single Phase | | | |
| Motor | 0.75 kW | 1.5 | kW | | |
| IP Rating / Insulation | I.P | . 44 Class F Insulati | ion | | |
| Motor Rating | | Continuous. | | | |
| Max Amperage | 5.5 A | 10.0 A | 11.5 A | | |
| Start Capacitor | 20uF | 40uF | 40uF | | |
| Pump materials | Cast iron pump body. S/S 304 Impeller | | | | |
| Mechanical Seal | Carbon / Ceramic | | | | |
| Inlet Size | 1" BSPF | 2" BSPF | 1 1/2" BSPF | | |
| Outlet Size | 1" BSPF 2" BSPF 1" BSPF | | | | |
| Maximum pressure | 8 bar | | | | |
| Working temp range | Ambiant temp max 40°C. Water temp 4 - 60°C | | | | |
| Power Cable | 2m H07 with 3 pin plug | | | | |
| Weight | 13.0 kg | 21 kg | 28 kg | | |
| ITEM CODE | 802805 | 802806 | 802816 | | |

| SPECIFICATIONS - Three Phase | | | | | |
|------------------------------|---|------------------|-----------|--|--|
| | FC300T | FC550T | FC750T | | |
| Maximum head | 28m | 54m | 56m | | |
| Maximum flow | 450 l/min | 500 l/min | 900 l/min | | |
| Input power | | 415V Three Phase | | | |
| Motor | 3.0 kW | 5.5 kW | 7.5 kW | | |
| IP Rating / Insulation | I.P. 44 Class F Insulation | | | | |
| Motor Rating | Continuous | | | | |
| Max Amperage | 8.2 | 13 | 16.5 | | |
| Pump materials | ump materials Cast iron pump body. S/S 304 Impeller | | | | |
| Mechanical Seal | Carbon / Ceramic | | | | |
| Inlet Size | 2" BSPF | | | | |
| Outlet Size | 2" BSPF | | | | |
| Maximum pressure | 8 bar | | | | |
| Working temp range | Ambiant temp max 40°C. Water temp 4 - 60°C | | | | |
| Weight | 42 kg | 62 kg | 67 kg | | |
| ITEM CODE | ITEM CODE 802808 802809 8028 | | 802810 | | |

7. Electrical Connections



Always use an electrical outlet that is protected by Residual Current Device (RCD) Safety Switch with a trip current of 30mA or less. A Safety switch is required by Australian/New Zealand Standard AU/NZS 60335.1-2011.

The mains supply voltage matches the voltage indicated on the pump identification plate.




Exercise care with the power cord.

Route the cord carefully to avoid potential snagging or chafing hazards.

Never lift the pump by the power cord or disconnect from the power supply by pulling the cord.


Single Phase pumps

Single Phase pumps are supplied with a 10 amp rated lead and AS/NZ 3112 (Type 1) 3 pin male power plug for connecting to mains power.




| BIANCO FC Series | Capacitors | uF |
|------------------|------------|----|
| FC75M | 805962 | 20 |
| FC150M | 805967 | 40 |
| FCT150M | 805460 | 45 |





Three Phase pumps

Three phase pumps must be installed by a licensed electrician and must have suitable overload protections installed.



Check rotation of the motor (three-phase motor). The motor fan should be spinning in a clockwise rotation. If the fan rotation is incorrect, isolate power to the pump and exchange the two supply wires.

8. General installation and startup notes

Following the basics will ensure your BiANCO NXT FC will perform reliably

- Install the pump on a firm base as close to your water source as practical and close to a suitable power supply.
- Avoid the use of extension cords as they can result in voltage drop. If an extension cord must be used ensure it is correctly rated.
- Protect the pump and controller from rain and moisture and minimise exposure to extremes of heat and cold. Operating range 2°C 40°C.



Install the pump in a weather- proof, free draining, well vented enclosure to protect
it from the extremes of temperature, moisture, flooding, chemicals, vermin, insects,
dust etc.

If the pump is drawing water from a supply below the level of the pump (suction lift), the pump will need to re-prime each time it starts or it may not prime at all. This can be mitigated by fitting a non-return valve to the end of the delivery line.

When the pump is controller with a Pressure switch, always install a pressure tank on the delivery side of the pump to prevent excessive pump starts per hour.

The intake suction piping is the most critical part of the installation. Errors or air leaks will cause significant issues for performance and pump reliability.






The pump and delivery line MUST be manually primed (filled) before the pump is started for the first time to ensure the mechanical seal is well lubricated. Dry operation causes irreparable damage to the mechanical seal.


Never start a pump until the pump chamber is filled with water.

Reminders of best practice:

Inlet pipe

- The inlet pipe must be the same size or larger than the inlet port size
- As short and straight as practical
- At least 200mm of straight pipe into the inlet. Avoid bends directly on the inlet






Inlet pipe

- Fit a non-return valve on the inlet piping
- An isolating valve on the inlet is recommended
- Unions allow for easy connection/disconnection
- Avoid piping which may result in air pockets


Avoid strain on the pump casing by supporting your pipework.



Mount the pump on a firm base in a dry, free draining area

Protect the pump from weather, dust, insects and extremes of temperature

9. Exploded View



| 1 | Pump Body (Volute) | 8 | Stator | |
|---|-----------------------------|-------|--------------------------------------|--|
| 2 | Impeller - SS304 | 9 | Terminal Box - ABS | |
| 3 | O-ring | 10 | Capacitor (Single phase models only) | |
| 4 | Mechanical Seal | 11 | Rotor | |
| 5 | Rear housing / seal support | 12 | Deep Groove Bearings | |
| 6 | Spacer section | 13 | Rear housing - Aluminium alloy | |
| 7 | Terminal board | 14,15 | Fan and Fan Cover | |

DANGER OF FROST: When the pump remains inactive for a long time at temperatures of less than 0°C, the pump body must be completely empty to prevent possible cracking of the hydraulic components.

Draining the pump is advisable even in the event of prolonged inactivity at normal temperature. When starting after long periods of inactivity, the start-up operations listed above must be repeated.

10. Warranties - Terms and Conditions

This warranty is given in addition to the consumer guarantees found within the Australian Competition and Consumer Act 2010 (Cth) for goods purchased in Australia and the Consumer Guarantees Act 1993 NZ for goods purchased in New Zealand:



- 1) White International Pty Ltd / White International NZ Ltd (White International) warrant that all products distributed are free from defects in workmanship and materials, for their provided warranty period as indicated on the top or opposite side of this document. Subject to the conditions of the warranty, White International will repair any defective products free of charge at the premises of our authorised service agents throughout Australia and New Zealand if a defect in the product appears during the warranty period. If you believe that you have purchased a defective product and wish to make a claim under this warranty, contact us on our Sales Hotline on 1300 783 601, or send your claim to our postal address or fax line below and we will advise you as to how next to proceed. You will be required to supply a copy of your proof of purchase to make a claim under this warranty.
- 2) This warranty excludes transportation costs to and from White International or its appointed service agents and excludes defects due to non-compliance with installation instructions, neglect or misuse, inadequate protection against the elements, low voltage or use or operation for purposes other than those for which they were designed. For further information regarding the suitability of your intended application contact us on our Sales Hotline on 1300 783 601. If you make an invalid claim under this warranty, the original product will be sent back to you unrepaired.
- 3) This warranty refers only to products sold after the 1st January 2012, and is not transferable to another product type and only applies to the original owner, purchaser or end user, and is in addition to the consumer guarantees found within the Competition and Consumer Act 2010 (Cth) for goods purchased in Australia and the Consumer Guarantees Act 1993 (NZ) for goods purchased in New Zealand.
- 4) Our goods come with guarantees that cannot be excluded under the Australian Consumer Law. You are entitled to a replacement or refund for a major failure and for compensation for any other reasonably foreseeable loss or damage. You are also entitled to have the goods repaired or replaced if the goods fail to be of acceptable quality and the failure does not amount to a major failure. 2 YEAR WARRANTY
- 5) To the fullest extent permitted by law, White International excludes its liability for all other conditions or warranties which would or might otherwise be implied at law. To the fullest extent permitted by law, White International's liability under this warranty and any other conditions, guarantees or warranties at law that cannot be excluded, including those in the Competition and Consumer Act 2010 (Cth), is expressly limited to: (a) in the case of products, the replacement of the product or the supply of equivalent product, the payment of the cost of replacing the product or of acquiring an equivalent product or the repair of the product or payment of the cost of having the product repaired, is at the discretion of White International or a 3rd party tribunal elected under the Competition and Consumer Act 2010 (Cth) for goods purchased in Australia and the Consumer Guarantees Act 1993 (NZ) for goods purchased in New Zealand; and
- 6) To the fullest extent permitted by law, this warranty supersedes all other warranties attached to the product or its packaging.
- 7) In the case of services, supplying the services again or the payment of the cost of having the services supplied again, is at the discretion of White International or a 3rd party tribunal elected under the Competition and Consumer Act 2010 (Cth) for goods purchased in Australia and the Consumer Guarantees Act 1993 (NZ) for goods purchased in New Zealand. 8) Our warranty commences from the date of purchase of the above mentioned pumps. Proof of purchase is required before consideration under warranty is given.

| Record your date of purchase in the space below | and retain this copy for your records. |
|---|--|
| Date of Purchase | .Model Purchased |

11. Trouble Shooting Guide

| | P | DSSIBLE CAUSE | PO | OTENTIAL SOLUTIONS |
|---|----|--|----|--|
| The pump | 1. | No electricity | 1. | Check the power supply. |
| won't start | 2. | Fuses or RCD tripped | 2. | Fuses or RCD tripped may indicate |
| and makes | | •• | | more serious problems |
| no noise | 3. | Internal motor fault | 3. | Contact an expert to check the motor |
| The pump doesn't start | 1. | Motor not free to turn i.e. internal jamming | 1. | Check whether pump can rotate freely |
| but makes a noise | 2. | Faulty capacitor | 2. | Contact an expert to check/replace capacitor |
| | 1. | Valves closed | 1. | Check suction and discharge isolating valves |
| The pump | 2. | Air entering suction line (loss of prime) | 2. | Check for leaks and ensure all joins or fittings are sealed |
| runs but | 3. | The water lavel may be too low | 3. | Check water availability |
| there is no | 4. | Pump may be worn or damaged | 4. | Contact your service agent for repair |
| flow or only poor flow | 5. | Blockages in the pump, suction or discharge lines | 5. | Contact your service agent for repair |
| | 6. | In-line filters blocked (if fitted) | 6. | Clean any filters/strainers in the system |
| | 7. | The piping may be too long or too small | 7. | Contact your pump professional |
| | 1. | Excessive flow demand | 1. | Check that the pump selected is correct |
| The pump runs. | 2. | Total head requirement too great for the | 2. | for the application Check the pump specification |
| There is flow | | pump | | |
| but poor | 3. | Pump may be worn or damaged | 3. | Contact your service agent |
| pressure | 4. | Air entering suction line reducing performance | 4. | Ensure the suction line is sealed |
| | 1. | Small water draw off or leak | 1. | correctly Check for small leaks i.e. taps or cistern |
| Pump cycling on | 2. | Leak in suction or discharge line | 2. | Check for leaks including suction line non return valve |
| and off | 3. | Contamination in the controller | 3. | Contact your service agent to inspect |
| Pump runs intermittently | 1. | Overheating and thermal protection tripping | 1. | Ensure the water temp is less than 40 deg C. Ensure sufficient airflow to cool the motor. Note that low voltage can cause the |
| | | | | motor to overheat. |
| | 1. | Incorrectly mounted/fixed | 1. | Ensure the pump is solidly attached to a base |
| | 2. | Internal blockage causing impeller | 2. | Contact your service agent |
| Bump | 2 | imbalance | 2 | Paduos the water demand to see if the |
| Pump vibrates and | 3. | If the flow requirement is greater than the | 3. | Reduce the water demand to see if the |
| | | pump is capable of it will cavitate. Cavitation sounds like gravel inside pump. | | noise disappears. |
| is noisy | | Cavitation sources like graver inside pump. | | Ensure the suction pipe is sized correctly. |
| | | | | A different pump model may be |
| | | | | required |
| | | | | Contact your service agent |
| Water | 1 | | | , , , , , , , , , , , , , , , , , , , |
| leaking from the centre of the pump | 1. | The mechanical seal is leaking | 1. | Contact your service agent for repair |
| and pump | 1 | | 1 | |



www.whiteint.com.au www.whiteint.co.nz

Please always refer to our website for further technical information & new product innovations

Disclaimer: Every effort has been made to publish the correct information in this manual. No responsibility will be taken for errors, omissions or changes in product specifications.

© 2024 Copyright White International Pty Ltd

TM ® - WARNING: Please be aware that various brands & products depicted within this document are subject to trademark, patent or design registrations. Infringement of any intellectual property contained within this document without express written authority by the appropriate intellectual property holder may result in further legal action to be taken. For any queries regarding use of the contained information please feel free to contact White International Pty Ltd.